


Dry plaster board

- 12.5mm dry lining board (1)
- JUPITER 16mm pipe (2)
- JUPITER System element (3)
- Wall fixings (4)

Construction data			Remarks
Construction thickness	mm	42.5	Thickness excluding wall
Thermal resistance R	m ² K/W	0.86	No insulation within construction
Plaster board	mm	12.5	1
JUPITER system pipe	mm	16 x 2	
JUPITER system element	mm	1000x500x30	
Wall fixings / Rawplugs	mm	75	9 holes /m ² pre-drilled. Countersunk screws holes to be filled
JUPITER wall fixings – 3 part	mm	75	
Wall finishes			Wall paper, paint, tiles
Pipe spacing	EZ: CZ:	mm	125 250
Additional information			Substrate must be solid, level and flat. See floor tolerance table DIN 18202, table 3, part 4 All manufacturer installation procedures should be observed.

Construction W3



Area of application

- 1 Dry lining element
Fermacell 12.5mm board
Heat exchange coefficient 0,31
Max. flow temp. 50°

